



International Fire Protection, Inc. has been contracted to install a CPVC Fire Sprinkler system for this project.

In compliance with the CPVC pipe manufacturer's recommendations, we are hereby notifying all parties that may be working around, or come in contact with the CPVC material on this project, of the precautions that must be followed to ensure a defect free fire sprinkler system.

International Fire Protection, Inc. will provide an installation that is in 100% compliance with these guidelines but cannot be responsible for the willful or negligent actions of other parties. Should any party violate these requirements, said party shall be financially responsible for any corrective actions required to repair the system as determined by the CPVC manufacturer, local jurisdiction, General Contractor or Owner. International Fire Protection, Inc. hereby expressly disclaims any liability or responsibility for any damage caused by any violation of those requirements and guidelines.

These guidelines are;

- DO NOT stack, support, hang equipment, or hang flexible wire/cable, especially communications cable, or other material on the fire sprinkler system.
- DO NOT expose CPVC products to incompatible substances, such as cutting oils, non-water-based paints, packing oils, traditional pipe thread paste and dope, fungicides, termiticides, insecticides, detergents, bulking caulking, adhesive tape, solder flux, flexible wire/cable (with special consideration for communications cabling), and non-approved spray foam insulation materials.
- DO NOT expose CPVC products to edible oils, solvents, or glycol-based anti-freeze fluids.
- DO NOT expose CPVC products to open flame, solder, and soldering flux.
- DO NOT drop, distort, or impact CPVC products or allow objects to be dropped on them.
- DO NOT handle CPVC products with gloves contaminated with oils (hydrocarbons) or other incompatible materials.
- DO NOT inject system with Microbiologically Controlled Corrosion ("M.I.C.") inhibitors unless they are listed in combination with this system.

Failure to follow this notice may cause cracks or fractures to develop in CPVC products resulting in the system potentially not working properly in the event of a fire and/or property damage due to leaks or flooding. The presence of any visible cracks may require partial or full system replacement.

For additional information contact:

International Fire Protection, Inc.
813-754-1383

NOTICE

This building contains a CPVC fire sprinkler system. This CPVC fire sprinkler system is a Life Safety Assembly and must be treated carefully. Please read the following before any activity which could contact this system:

CPVC piping components may be damaged by certain substances and construction practices.

- DO NOT stack, support, hang equipment, or hang flexible wire/cable, especially communications cable, or other material on the fire sprinkler system.
- ONLY system compatible materials including, but not limited to solvent cements, caulks, sealants, cutting oils and thread pastes as noted by the CPVC fire sprinkler piping system manufacturer's installation instructions should be used in contact with this system.
- DO NOT expose CPVC products to incompatible substances, such as cutting oils, non-water based paints, packing oils, traditional pipe thread paste and dope, fungicides, termiticides, insecticides, detergents, building caulks, adhesive tape, solder flux, flexible wire/cable (with special consideration for communications cabling), and non-approved spray foam insulation materials.
- DO NOT expose CPVC products to edible oils, solvents, or glycol-based anti-freeze fluids.
- DO NOT expose CPVC products to open flame, solder, and soldering flux.
- DO NOT drop, distort, or impact CPVC products or allow objects to be dropped on them.
- DO NOT handle CPVC products with gloves contaminated with oils (hydrocarbons) or other incompatible materials.

Failure to follow this notice may cause cracks or fractures to develop in CPVC products resulting in property damage due to leaks or flooding. The presence of any visible cracks may require partial or full system replacement. For additional information contact the general contractor or the fire sprinkler system installer.



FOR ADDITIONAL INFORMATION CONTACT
SPEARS® MANUFACTURING COMPANY AT 1-800-862-1499